

Nominated Smoke Alarms

Nominated Smoke Alarms Requirements

- Photoelectric
- Non-removable 10 year battery
- “Replace by” on the side of device
- Certified to AS 3786:2014

<p>Brooks</p>	<p>EIB166e (Mains powered w/back-up battery)</p>	 <p>Brooks EIB166e Mains Power</p>
<p>Brooks</p>	<p>EIB650iC (Battery powered only)</p>	 <p>Brooks EIB650iC Battery Powered</p>
<p>PSA</p>	<p>LIF5800RL/2 (Mains powered w/back-up battery)</p>	 <p>PSA LIF5800RL/2 Mains Power</p>
<p>PSA</p>	<p>LIFPE10 (Battery powered only)</p>	 <p>PSA LIFPE10 Battery Powered</p>

Nominated Smoke Alarms Wireless Module Requirements

- Certified to AS/NZS4268:2012

Brooks	EIB100MRF (to suit EIB166e)	
Brooks	EIB600MRF (to suit EIB650iC)	
PSA	LIFWMB	 <p data-bbox="852 1279 1477 1310">PSA LIFSAVER Wireless Interconnect Base LIFWMB</p>

Previous Nominated Smoke Alarms (Acceptable if existing in properties - CANNOT be installed)

<p>PSA Lifesaver</p>	<p>LIF4800RL DISCONTINUED 1 MAR 2011 (PHASED OUT BY 2020)</p>	
<p>PSA Lifesaver</p>	<p>LIF5800RL DISCONTINUED 1 MAY 2017 (PHASED OUT BY 2028)</p>	 <p>Note: There are many PSA model alarms on the market with the HUSH button. Visually, the only way to distinguish the approved version is by sighting the model number displayed on the outside of the alarm in addition to testing procedures. If the model number LIF5800RL is not displayed on the alarm then the alarm does not comply and must be replaced as per mandatory reporting procedures.</p>
<p>Brooks</p>	<p>EIPFSPTLH DISCONTINUED 1 MAY 2017 (PHASED OUT BY 2028)</p>	
<p>Brooks</p>	<p>EIB605TYC DISCONTINUED 1 MAY 2017 (PHASED OUT BY 2028)</p>	

